



EAST LINTON DRINKING WATER SYSTEM

PERFORMANCE REPORT

**For the period of
JANUARY 1, 2024 to JULY 31, 2024**

Prepared by: Karla Young, Process & Compliance Technician

Reviewed by: Leo-Paul Frigault, Senior Operations Manager



1. Process Performance & Regulatory Compliance

1.1 Summary of Non-Compliances & AWQIs

From **January 2024 to July 2024**:

- Number of Non-Compliances = **0**
- Number of Adverse Water Quality Incidents (AWQIs) = **0**

The table below summarizes East Linton DWS' performance in accordance with the regulatory limits set out in:

- Municipal Drinking Water License (MDWL) 083-105, (Issue: 4) (expires August 13, 2026)
- Permit To Take Water (PTTW) 6203-AKNKQW
- Ontario Regulation 170/03

2024	Non-Compliances	AWQIs
January	0	0
February	0	0
March	0	0
April	0	0
May	0	0
June	0	0
July	0	0
August		
September		
October		
November		
December		

Description of Non-Compliances

The following is a summary of the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water license, and any orders applicable to the system that were not met at any time during the time period covered by this report; as well as the duration of the failure and the measures that were taken to correct the failure:

Non-Compliance(s)	Duration	Required Actions & Corrective Actions
n/a	n/a	n/a

Description of AWQIs

The following contains details on notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to the Spills Action Centre:

Date of Incident	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
n/a	n/a	n/a	n/a	n/a	n/a

1.1.1 Flow


Raw Water

During the reporting period, raw water taking for the East Linton DWS was **within the limits** of the current PTTW.

2024	Maximum Flowrate (L/s)	Within Limits (30 L/s*)	Maximum Daily Flow (m ³ /day)	Within Limits (2,600 m ³)
January	27.69	Yes	1,077	Yes
February	27.54	Yes	653	Yes
March	27.55	Yes	1,079	Yes
April	27.64	Yes	881	Yes
May	27.78	Yes	1,032	Yes
June	27.84	Yes	1,080	Yes
July	28.00	Yes	1,122	Yes
August				
September				
October				
November				
December				

*The PTTW defines the maximum flowrate as 1,800 L/min which has been converted it to 30 L/s for the table above.

**East Linton Drinking Water System
 Raw Water - Maximum Daily Flows**




Township of Georgian Bluffs
 East Linton Drinking Water System
 Performance Report: January 1, 2024 to July 31, 2024

Treated Water


During the reporting period, the East Linton DWS operated **within the rated capacity** set out in current MDWL.

2024	Average Flow (m ³ /day)	% of Rated Capacity	Maximum Flow (m ³ /day)	% of Rated Capacity	Within Limits (2,600 m ³ /day)
January	755	29.0%	1,108	42.6%	Yes
February	609	23.4%	677	26.0%	Yes
March	624	24.0%	1,032	39.7%	Yes
April	669	25.7%	885	34.0%	Yes
May	775	29.8%	1,114	42.8%	Yes
June	786	30.2%	1,073	41.3%	Yes
July	827	31.8%	1,140	43.8%	Yes
August					
September					
October					
November					
December					

**East Linton Drinking Water System
 Treated Water - Maximum Daily Flows**



East Linton Drinking Water System Treated Water - Average Daily Flows



1.1.1 Water Quality

Microbiological Testing

Raw Water*

2024	# of Samples	E.Coli (cfu/100mL)			Total Coliforms (cfu/100mL)		
		Minimum	Maximum	Within Limits?	Minimum	Maximum	Within Limits?
January	5	0	1	n/a	0	66	n/a
February	4	0	0	n/a	0	13	n/a
March	4	0	0	n/a	1	6	n/a
April	5	0	1	n/a	0	20	n/a
May	4	0	2	n/a	0	33	n/a
June	4	0	0	n/a	0	1	n/a
July	5	0	0	n/a	0	33	n/a
August							
September							
October							
November							
December							

*Raw water bacteriological samples do not have regulatory limits.

Township of Georgian Bluffs
 East Linton Drinking Water System
 Performance Report: January 1, 2024 to July 31, 2024

Treated Water

2024	# of Samples	E. Coli (cfu/100mL)			Total Coliforms (cfu/100mL)			HPC** (cfu/1mL)		
		Min	Max	Within Limits?	Min	Max	Within Limits?	Min	Max	Within Limits?
January	5	0	0	Yes	0	0	Yes	0	1	n/a
February	4	0	0	Yes	0	0	Yes	0	1	n/a
March	4	0	0	Yes	0	0	Yes	0	0	n/a
April	5	0	0	Yes	0	0	Yes	0	0	n/a
May	4	0	0	Yes	0	0	Yes	0	1	n/a
June	4	0	0	Yes	0	0	Yes	0	0	n/a
July	5	0	0	Yes	0	0	Yes	0	1	n/a
August										
September										
October										
November										
December										

**There is no regulatory limit for Heterotrophic Plate Count (HPC); it is used as an indicator test.

Distribution Water

2024	# of Samples	E. Coli (0 cfu/100mL)			Total Coliforms (0 cfu/100mL)		
		Min.	Max.	Within Limits?	Min.	Max.	Within Limits?
January	11	0	0	Yes	0	0	Yes
February	9	0	0	Yes	0	0	Yes
March	9	0	0	Yes	0	0	Yes
April	11	0	0	Yes	0	0	Yes
May	9	0	0	Yes	0	0	Yes
June	9	0	0	Yes	0	0	Yes
July	11	0	0	Yes	0	0	Yes
August							
September							
October							
November							
December							

Township of Georgian Bluffs
 East Linton Drinking Water System
 Performance Report: January 1, 2024 to July 31, 2024

	HPC** (cfu/1mL)			
	# of Samples	Min.	Max.	Within Limits?
January	5	0	1	n/a
February	4	0	1	n/a
March	4	0	1	n/a
April	5	0	0	n/a
May	4	0	0	n/a
June	4	0	0	n/a
July	5	0	1	n/a
August				
September				
October				
November				
December				

**There is no regulatory limit for Heterotrophic Plate Count (HPC); it is used as an indicator test. At least 25% of distribution samples must be tested for Heterotrophic Plate Count (HPC).

Operational Testing

Filter Effluent: Turbidity

2024	Filter #1 Turbidity (NTU)		Filter #2 Turbidity (NTU)	
	Minimum	Maximum	Minimum	Maximum
January	0.009	0.027	0.021	0.031
February	0.010	0.018	0.020	0.036
March	0.009	0.099	0.011	0.081
April	0.010	0.053	0.013	0.063
May	0.018	0.023	0.012	0.057
June	0.017	0.029	0.015	0.039
July	0.017	0.026	0.013	0.039
August				
September				
October				
November				
December				

Township of Georgian Bluffs
 East Linton Drinking Water System
 Performance Report: January 1, 2024 to July 31, 2024

Filter Effluent: Efficiency

2024	Filter #1		Filter #2	
	Efficiency (% ≤ 0.1 NTU)	Within Limits? ($\geq 99\%$)	Efficiency (% ≤ 0.1 NTU)	Within Limits? ($\geq 99\%$)
January	100%	Yes	100%	Yes
February	100%	Yes	100%	Yes
March	100%	Yes	100%	Yes
April	100%	Yes	100%	Yes
May	100%	Yes	100%	Yes
June	100%	Yes	100%	Yes
July	100%	Yes	100%	Yes
August				
September				
October				
November				
December				

Distribution Water: Free Chlorine Residual

2024	Minimum (mg/L)	Maximum (mg/L)	Within Limits? (> 0.05 mg/L)
January	1.08	2.06	Yes
February	0.93	1.87	Yes
March	1.00	1.79	Yes
April	0.99	1.91	Yes
May	0.93	1.66	Yes
June	0.86	1.68	Yes
July	0.65	1.60	Yes
August			
September			
October			
November			
December			

Township of Georgian Bluffs
 East Linton Drinking Water System
 Performance Report: January 1, 2024 to July 31, 2024

Quarterly Samples

Treated Water: Nitrites

2024	Concentration (mg/L)	Within Limits? (1 mg/L)
January	<0.003	Yes
February	-	-
March	-	-
April	<0.003	Yes
May	-	-
June	-	-
July	<0.003	Yes
August	-	-
September	-	-
October	-	-
November	-	-
December	-	-

Treated Water: Nitrates

2024	Concentration (mg/L)	Within Limits? (10 mg/L)
January	0.256	Yes
February	-	-
March	-	-
April	0.260	Yes
May	-	-
June	-	-
July	0.250	Yes
August	-	-
September	-	-
October	-	-
November	-	-
December	-	-

Township of Georgian Bluffs
 East Linton Drinking Water System
 Performance Report: January 1, 2024 to July 31, 2024

Distribution Water: Trihalomethanes (THMs)

2024	Concentration (µg/L)	Running Annual Average (µg/L)	Within Limits? (100 µg/L)
January	44	47	Yes
February	-	-	-
March	-	-	-
April	49	47.5	Yes
May	-	-	-
June	-	-	-
July	53	49.0	Yes
August	-	-	-
September	-	-	-
October	-	-	-
November	-	-	-
December	-	-	-

Distribution Water: Haloacetic Acids (HAAs)

2024	Concentration (µg/L)	Running Annual Average (µg/L)	Within Limits? (80 µg/L)
January	14.3	16.8	Yes
February	-	-	-
March	-	-	-
April	11.7	16.4	Yes
May	-	-	-
June	-	-	-
July	13.4	14.1	Yes
August	-	-	-
September	-	-	-
October	-	-	-
November	-	-	-
December	-	-	-

Semi-Annual Samples

Distribution Water: Lead, pH and Alkalinity

Semi-Annual sampling is required to happen twice a year; once in the period from December 15th to April 15th and once in the period June 15th to October 15th for lead, pH and Alkalinity.

	# of Samples	Lead (µg/l)			pH			Alkalinity (mg/L)		
		Min	Max	Within Limits? (10 µg/L)	Min	Max	Within Limits?	Min	Max	Within Limits? (30-500 mg/L)
January	-	-	-	-	-	-	-	-	-	-
February	2	-	-	-	8.01	8.08	Yes	75	75	Yes
March	-	-	-	-	-	-	-	-	-	-
April	-	-	-	-	-	-	-	-	-	-
May	-	-	-	-	-	-	-	-	-	-
June	-	-	-	-	-	-	-	-	-	-
July	-	-	-	-	-	-	-	-	-	-
August	-	-	-	-	-	-	-	-	-	-
September	-	-	-	-	-	-	-	-	-	-
October	-	-	-	-	-	-	-	-	-	-
November	-	-	-	-	-	-	-	-	-	-
December	-	-	-	-	-	-	-	-	-	-

Annual Samples

Treated Water: Schedule 23 & Schedule 24

Treated water Inorganic and Organic chemicals were last tested on **January 31, 2024**; the sample results were **within the regulatory limits** set out in O.Reg 169/03. The next set of Schedule 23 and Schedule 24 samples is scheduled to be taken in **January 2025**.

60 Month Samples

Treated Water: Sodium

No samples were for Sodium and Fluoride were required to be taken during the reporting period.

Treated water Sodium was last sampled on **April 12, 2021** and was within regulatory limits. The next set of Sodium samples are scheduled for **April 2026**.

Treated Water: Fluoride

Treated water Fluoride was last sampled on **April 12, 2021** and was within regulatory limits. The next set of Sodium samples are scheduled for **April 2026**.

1.2 Reporting

A summary of the reports submitted by OCWA to/on behalf of the Township are summarized in the table below:

Report	Submission Frequency	Submit To	Submission Date
Annual Report (Section 11)	Annually	Owner	February 26, 2024
Summary Report (Schedule 22)	Annually	Owner	February 26, 2024

1.2.1 Annual Report (Section 11)

As required by Section 11 of O. Reg 170/03, OCWA prepares a report for the Township that covers the period from January 1 to December 31 by no later than February 28 of the following year. The annual report must:

- a) contain a brief description of the drinking water system, including a list of water treatment chemicals used by the system during the period covered by the report;
- b) summarize any reports made to the Ministry under subsection 18 (1) of the Act or section 16-4 of Schedule 16 during the period covered by the report;
- c) summarize the results of tests required under this Regulation, or under an approval, municipal drinking water licence or order, including an OWRA order, during the period covered by the report and, if tests required under this Regulation in respect of a parameter were not required during that period, summarize the most recent results of tests of that parameter;
- d) describe any corrective actions taken under Schedule 17 or 18 during the period covered by the report;
- e) describe any major expenses incurred during the period covered by the report to install, repair or replace required equipment;
- f) in the case of a large municipal residential system or a small municipal residential system, include a statement of where a report prepared under Schedule 22 will be available for inspection under subsection 12 (4); and
- g) in the case of a large municipal residential system, small municipal residential system or non-municipal year-round residential system, specify the number of points sampled during the periods described in subsection 15.1-4 (2) or subsection 15.1-5 (5) of Schedule 15.1 to the Regulation, the number of samples taken, and the number of points where a sample exceeded the prescribed standard for lead during those periods. O. Reg. 170/03, s. 11 (6); O. Reg. 418/09, s. 8; O. Reg. 458/16, s. 6 (1).

“The owner of a drinking water system shall ensure that a copy of an annual report for the system is given, without charge, to every person who requests a copy. If a drinking water system is connected to and receives all of its drinking water from another drinking water system, the owner of the system that obtains the water shall ensure that a copy of an annual report for the system from which the water is obtained is given, without charge, to every person who requests a copy. Every time that an annual report is prepared for a drinking water system, the owner of the system shall ensure that effective steps are taken to advise users of water from the system that copies of the report are available, without charge, and of how a copy may be obtained. If the DWS serves more than 10,000 people, the owner of the system shall ensure that a copy of every report prepared under this section is available to the public at no charge on a website on the Internet.”

1.2.2 Summary Report (Schedule 22)

As required by Schedule 22 of O. Reg 170/03 OCWA prepares a report on behalf of the Township by no later than March 31 each year for the preceding year. This report is to be given to members of council.

“The report must,

- a) List the requirements of the Act, the regulations, the system’s approval, drinking water works permit, municipal drinking water licence, and any orders applicable to the system that were not met at any time during the period covered by the report; and
- b) For each requirement referred to that was not met, specify the duration of the failure and the measures that were taken to correct the failure.

The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system’s approval, drinking water works permit or municipal drinking water licence, or if the system is receiving all of its water from another system under an agreement pursuant to subsection 5 (4), to the flow rates specified in the written agreement.”

1.3 Third Party Inspections & Results

There was a Ministry of Environment, Conservation and Parks (MECP) inspection on **May 23, 2024**. The inspection report was received on **June 13, 2024** with an inspection rating of **100%**.

1.4 Drinking Water Quality Management Standard (DWQMS)

Refer to Section 1.4 in the Shallow Lake DWS Performance Report for the reporting period for more information.

1.4.1 Risk Assessment

Refer to Section 1.4.1 in the Shallow Lake DWS Performance Report for the reporting period for more information.

1.4.2 Review & Provision of Infrastructure

Refer to Section 1.4.2 in the Shallow Lake DWS Performance Report for the reporting period for more information.

1.4.3 Internal Audits

Refer to Section 1.4.3 in the Shallow Lake DWS Performance Report for the reporting period for more information.

1.4.4 External Audits

Refer to Section 1.4.4 in the Shallow Lake DWS Performance Report for the reporting period for more information.

1.4.5 Management Review

Refer to Section 1.4.5 in the Shallow Lake DWS Performance Report for the reporting period for more information.

2. Operations & Maintenance

2.1 Major & Unscheduled Maintenance

January

- 02:** Performed chemical wash on Skid B
- 04:** Water turn on at 543 Punkinseed Ln
- 11:** Overnight leak detection performed
- 16:** Installed electric actuated valve for bulk water station

February

- 26:** Cleaned UV #2
- 27:** Replaced hypochlorite pump #1 tank feed tubing

March

- 06:** UV #2 Maintenance
- 09:** PLC replacement
- 10:** Replaced supply tubing for chlorine analyzer
- 18:** Installed HMI panel view into control panel
- 19:** Annual backflow prevention testing

April

- 03:** Third party flow meter verification
- 29:** Rebuilt chlorine pump #2

May

- 21:** Third party instrumentation calibrations
- 23:** MECP onsite inspection
- 30:** Watermain tapping on Alexandria St.

June

- 21:** Water turn on at 518 Algonquin Trail

July

No major or unscheduled maintenance during this time period. All scheduled maintenance completed.

2.2 Call-Ins

January

There were no call-ins for this month.

February

There were no call-ins for this month.

March

- 18:** Distribution critical alarm

April

- 05:** PALL system alarm

Township of Georgian Bluffs
East Linton Drinking Water System
Performance Report: January 1, 2024 to July 31, 2024

- 11:** PALL system alarm
- 13:** Communication failure alarm
- 15:** Communication failure alarm
- 28:** Communication failure alarm

May

- 01:** PALL system alarm
- 05:** Distribution system critical

June

- 02:** PALL system alarm
- 13:** PALL system alarm

July

There were no call-ins for this month.

2.4 Community Complaints

January

There were no complaints or public inquiries reported to OCWA staff during this month.

February

- 5:** Township of Georgian Bluffs staff conveyed that the resident from 157 Cobble Beach Drive reported low pressure concerns on January 17th, 2024. Township staff suggested to the resident to contact a licensed plumber to discuss the potential benefit of adding a booster pump or pressure tank to increase the pressure on the private side.

March

There were no complaints or public inquiries reported to OCWA staff during this month.

April

There were no complaints or public inquiries reported to OCWA staff during this month.

May

There were no complaints or public inquiries reported to OCWA staff during this month.

June

There were no complaints or public inquiries reported to OCWA staff during this month.

July

There were no complaints or public inquiries reported to OCWA staff during this month.

3. Health & Safety

3.1 Incidents

- Number of Health & Safety Incidents Reported = 0

2024	Health & Safety Incidents	
	# Reported	Details
January	0	n/a
February	0	n/a
March	0	n/a
April	0	n/a
May	0	n/a
June	0	n/a
July	0	n/a
August		
September		
October		
November		
December		

3.2 Training

Refer to the Shallow Lake DWS Performance Report for safety topics/training provided to staff during this reporting period.